



**AIR MOVEMENT AND CONTROL  
ASSOCIATION INTERNATIONAL, INC.**

International Headquarters  
30 West University Drive  
Arlington Heights, Illinois  
60004-1893 USA

Phone: 847-394-0150  
Fax: 847-253-0088  
E-Mail: [jparent@amca.org](mailto:jparent@amca.org)  
Website: [www.amca.org](http://www.amca.org)

**Test No. 28024-S1**

November 04, 2011

TO: Aireng Company  
Plot # 08, SECTOR I-11/4  
Industrial Area  
Islamabad, Punjab PAKISTAN 44000

ATTN: Ahmed Saeed  
[saeed@airengindustries.com](mailto:saeed@airengindustries.com)

**SUBJECT: CONTRACT TESTING  
MODEL No. 15D**

Attached are the test results of the subject model performed on October 29, 2011.

If you should have any questions concerning these data, please let us know.

Sincerely,  
AIR MOVEMENT AND CONTROL  
ASSOCIATION INTERNATIONAL, INC.

Josh Parent  
Laboratory Manager

Attachment

Copy To: [saeed@airengindustries.com](mailto:saeed@airengindustries.com)

**TEST INFORMATION**

Test Number : 28024-S1  
Purpose : Contract Test

Date of Test : 29 Oct 2011  
Technician : LTH

**UNIT INFORMATION**

Customer : Aireng Company  
Unit Manufacturer : Aireng Company  
Type : Centrifugal  
Trade Name : ABIC  
Model Number : 15D  
No. of Blades : 12  
Blade Setting : NA  
No. of Stator Vanes : NA  
Impeller Diameter : 0.384 m  
Inlet Area : 0.1134 m<sup>2</sup>  
Outlet Area : 0.229 m<sup>2</sup>  
Effective Duct Diameter : 0.38 m

**TEST CONFIGURATION**

Setup : AMCA Standard 300, Figure 2, Inlet Sound  
Installation Type : B - Free Inlet, Ducted Outlet  
Installation Notes : -

**TEST ENVIRONMENT**

Pb : 1005.9 h.Pa  
tdo : 31.1 °C  
two : 23.8 °C

**Comments**

Unit tested with AFMA built outlet duct  
Air Volume taken from 28024-A1 dated 29 Oct 2011

**Important Notes**

*Data exist where the background clearance of the test unit ( $L_{PM} - L_{PB}$ ) does not meet the 6dB criteria required by AMCA Standard 300-05. These data are labeled with an asterisk (\*)*

## RSS MEASUREMENT

Test Number 28024-S1  
 Purpose Contract Test

Date of Test 29 Oct 2011  
 Technician LTH

### Reference Sound Source

AMCA Band Number	1			2			3			4		
Center Frequency (Hz)	<u>50</u>	<u>63</u>	<u>80</u>	<u>100</u>	<u>125</u>	<u>160</u>	<u>200</u>	<u>250</u>	<u>315</u>	<u>400</u>	<u>500</u>	<u>630</u>
L <sub>pqm</sub>	50.6	59.8	61.0	63.5	66.5	67.6	68.4	69.6	70.2	70.1	71.0	71.5
L <sub>pb</sub>	43.3	37.9	38.0	41.4	40.8	39.7	38.6	34.7	34.1	27.0	26.2	25.1
L <sub>pqm</sub> - L <sub>pb</sub>	7.3	21.9	23.0	22.1	25.7	27.9	29.9	34.9	36.2	43.1	44.8	46.4
L <sub>pqm</sub> - L <sub>pq</sub>	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
L <sub>pq</sub>	49.8	59.8	60.9	63.5	66.4	67.6	68.4	69.6	70.2	70.1	71.0	71.5
L <sub>Wr</sub>	77.2	78.6	78.9	79.9	79.7	80.0	80.3	80.4	80.5	80.6	80.8	81.6
L <sub>Wr</sub> - L <sub>pq</sub>	27.4	18.8	18.0	16.4	13.3	12.4	11.9	10.8	10.3	10.5	9.8	10.1
AMCA Band Number	5			6			7			8		
Center Frequency (Hz)	<u>800</u>	<u>1.0K</u>	<u>1.3K</u>	<u>1.6K</u>	<u>2.0K</u>	<u>2.5K</u>	<u>3.2K</u>	<u>4.0K</u>	<u>5.0K</u>	<u>6.3K</u>	<u>8.0K</u>	<u>10.0K</u>
L <sub>pqm</sub>	73.3	74.5	75.5	75.7	75.5	73.9	72.2	72.0	71.1	69.3	66.6	63.4
L <sub>pb</sub>	23.0	18.8	15.7	14.5	11.2	10.2	7.3	6.6	7.5	7.0	7.7	8.4
L <sub>pqm</sub> - L <sub>pb</sub>	50.3	55.6	59.8	61.2	64.2	63.8	64.8	65.4	63.6	62.2	58.8	55.0
L <sub>pqm</sub> - L <sub>pq</sub>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
L <sub>pq</sub>	73.3	74.5	75.5	75.7	75.5	73.9	72.2	72.0	71.1	69.3	66.6	63.4
L <sub>Wr</sub>	83.4	84.6	85.6	86.0	86.7	85.4	84.2	84.4	83.9	82.9	80.8	79.1
L <sub>Wr</sub> - L <sub>pq</sub>	10.1	10.1	10.1	10.3	11.2	11.5	12.0	12.4	12.8	13.6	14.2	15.7

These test data were obtained in a laboratory accredited by AMCA for AMCA Standard 300 testing. Data are not certified by AMCA.

## MEASUREMENT

Test Number 28024-S1  
 Purpose Contract Test

Test Date 29 Oct 2011  
 Technician LTH

### Determination Number 1

AMCA Band Number	1			2			3			4		
Center Frequency (Hz)	<u>50</u>	<u>63</u>	<u>80</u>	<u>100</u>	<u>125</u>	<u>160</u>	<u>200</u>	<u>250</u>	<u>315</u>	<u>400</u>	<u>500</u>	<u>630</u>
L <sub>pm</sub>	49.4	60.1	63.0	66.4	71.3	71.3	69.4	71.1	74.1	78.3	73.8	70.5
L <sub>pb</sub>	43.2	38.8	39.6	43.1	43.1	42.0	40.4	38.5	38.0	42.4	41.4	30.0
L <sub>pm</sub> - L <sub>pb</sub>	6.2	21.3	23.4	23.3	28.2	29.3	28.9	32.6	36.1	35.9	32.4	40.4
L <sub>pm</sub> - L <sub>pc</sub>	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
L <sub>pc</sub>	48.2	60.0	63.0	66.4	71.3	71.3	69.4	71.1	74.1	78.3	73.8	70.5
L <sub>Wr</sub> - L <sub>pq</sub>	27.4	18.8	18.0	16.4	13.3	12.4	11.9	10.8	10.3	10.5	9.8	10.1
E <sub>i</sub>	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
L <sub>Wmi</sub>	75.6	78.9	81.0	82.8	84.5	83.7	81.2	81.9	84.4	88.8	83.6	80.6

AMCA Band Number	5			6			7			8		
Center Frequency (Hz)	<u>800</u>	<u>1.0K</u>	<u>1.3K</u>	<u>1.6K</u>	<u>2.0K</u>	<u>2.5K</u>	<u>3.2K</u>	<u>4.0K</u>	<u>5.0K</u>	<u>6.3K</u>	<u>8.0K</u>	<u>10.0K</u>
L <sub>pm</sub>	73.3	69.1	69.0	68.3	67.1	66.9	63.9	62.6	58.8	58.3	50.5	47.5
L <sub>pb</sub>	28.7	23.1	18.5	17.5	14.3	19.5	15.6	15.1	10.8	25.6	29.0	13.8
L <sub>pm</sub> - L <sub>pb</sub>	44.7	46.1	50.6	50.8	52.8	47.4	48.3	47.5	48.1	32.7	21.5	33.7
L <sub>pm</sub> - L <sub>pc</sub>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
L <sub>pc</sub>	73.3	69.1	69.0	68.3	67.1	66.9	63.9	62.6	58.8	58.3	50.5	47.5
L <sub>Wr</sub> - L <sub>pq</sub>	10.1	10.1	10.1	10.3	11.2	11.5	12.0	12.4	12.8	13.6	14.2	15.7
E <sub>i</sub>	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
L <sub>Wmi</sub>	83.4	79.3	79.1	78.6	78.4	78.4	75.9	75.0	71.7	71.9	64.8	63.2

Test Conditions at Fan Inlet : Ps actual : 0.0 Pa      density: 1.140 kg/m<sup>3</sup>  
 Td1 : 31.1 °C      Pb : 100590 Pa

### Determination Number 2

AMCA Band Number	1			2			3			4		
Center Frequency (Hz)	<u>50</u>	<u>63</u>	<u>80</u>	<u>100</u>	<u>125</u>	<u>160</u>	<u>200</u>	<u>250</u>	<u>315</u>	<u>400</u>	<u>500</u>	<u>630</u>
L <sub>pm</sub>	49.4	56.2	60.6	64.7	68.6	68.7	66.9	70.8	71.6	77.0	71.9	67.6
L <sub>pb</sub>	42.5	38.7	38.7	42.4	42.8	40.2	40.0	37.3	34.5	27.9	25.8	23.9
L <sub>pm</sub> - L <sub>pb</sub>	7.0	17.5	21.9	22.3	25.9	28.5	26.9	33.5	37.1	49.0	46.1	43.7
L <sub>pm</sub> - L <sub>pc</sub>	1.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
L <sub>pc</sub>	48.5	56.1	60.5	64.7	68.6	68.7	66.9	70.8	71.6	77.0	71.9	67.6
L <sub>Wr</sub> - L <sub>pq</sub>	27.4	18.8	18.0	16.4	13.3	12.4	11.9	10.8	10.3	10.5	9.8	10.1
E <sub>i</sub>	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
L <sub>Wmi</sub>	75.9	75.0	78.5	81.2	81.9	81.1	78.8	81.6	81.9	87.4	81.7	77.7

AMCA Band Number	5			6			7			8		
Center Frequency (Hz)	<u>800</u>	<u>1.0K</u>	<u>1.3K</u>	<u>1.6K</u>	<u>2.0K</u>	<u>2.5K</u>	<u>3.2K</u>	<u>4.0K</u>	<u>5.0K</u>	<u>6.3K</u>	<u>8.0K</u>	<u>10.0K</u>
L <sub>pm</sub>	71.1	66.6	66.5	65.5	64.0	63.3	59.7	57.5	55.0	57.6	47.0	44.2
L <sub>pb</sub>	19.2	17.2	13.1	15.2	9.8	8.7	7.3	6.7	7.3	7.0	7.7	8.4
L <sub>pm</sub> - L <sub>pb</sub>	51.9	49.4	53.4	50.4	54.2	54.6	52.4	50.8	47.7	50.6	39.3	35.8
L <sub>pm</sub> - L <sub>pc</sub>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
L <sub>pc</sub>	71.1	66.6	66.5	65.5	64.0	63.3	59.7	57.5	55.0	57.6	47.0	44.2
L <sub>Wr</sub> - L <sub>pq</sub>	10.1	10.1	10.1	10.3	11.2	11.5	12.0	12.4	12.8	13.6	14.2	15.7
E <sub>i</sub>	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
L <sub>Wmi</sub>	81.2	76.7	76.6	75.8	75.2	74.8	71.7	69.9	67.8	71.2	61.3	59.9

Test Conditions at Fan Inlet : Ps actual : 374.4 Pa      density: 1.140 kg/m<sup>3</sup>  
 Td1 : 31.1 °C      Pb : 100590 Pa

## MEASUREMENT

Test Number 28024-S1  
Purpose Contract Test

Test Date 29 Oct 2011  
Technician LTH

### Determination Number 3

AMCA Band Number	1			2			3			4		
Center Frequency (Hz)	<u>50</u>	<u>63</u>	<u>80</u>	<u>100</u>	<u>125</u>	<u>160</u>	<u>200</u>	<u>250</u>	<u>315</u>	<u>400</u>	<u>500</u>	<u>630</u>
L <sub>pm</sub>	46.6	57.6	54.3	61.2	65.3	66.4	66.1	66.6	67.8	74.0	67.5	64.1
L <sub>pb</sub>	42.5	38.7	38.7	42.4	42.8	40.2	40.0	37.3	34.5	27.9	25.8	23.9
L <sub>pm</sub> - L <sub>pb</sub>	4.1*	18.9	15.6	18.8	22.5	26.2	26.1	29.3	33.3	46.0	41.7	40.2
L <sub>pm</sub> - L <sub>pc</sub>	1.3	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
L <sub>pc</sub>	45.3	57.5	54.2	61.1	65.3	66.4	66.1	66.6	67.8	74.0	67.5	64.1
L <sub>Wr</sub> - L <sub>pq</sub>	27.4	18.8	18.0	16.4	13.3	12.4	11.9	10.8	10.3	10.5	9.8	10.1
E <sub>i</sub>	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
L <sub>Wmi</sub>	72.7*	76.3	72.2	77.6	78.5	78.8	78.0	77.4	78.1	84.4	77.3	74.2

AMCA Band Number	5			6			7			8		
Center Frequency (Hz)	<u>800</u>	<u>1.0K</u>	<u>1.3K</u>	<u>1.6K</u>	<u>2.0K</u>	<u>2.5K</u>	<u>3.2K</u>	<u>4.0K</u>	<u>5.0K</u>	<u>6.3K</u>	<u>8.0K</u>	<u>10.0K</u>
L <sub>pm</sub>	67.6	62.9	62.9	60.9	59.5	58.5	54.9	52.7	50.7	57.1	43.3	42.2
L <sub>pb</sub>	19.2	17.2	13.1	15.2	9.8	8.7	7.3	6.7	7.3	7.0	7.7	8.4
L <sub>pm</sub> - L <sub>pb</sub>	48.4	45.7	49.8	45.7	49.7	49.7	47.5	46.0	43.3	50.1	35.5	33.7
L <sub>pm</sub> - L <sub>pc</sub>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
L <sub>pc</sub>	67.6	62.9	62.9	60.9	59.5	58.5	54.9	52.7	50.7	57.1	43.2	42.2
L <sub>Wr</sub> - L <sub>pq</sub>	10.1	10.1	10.1	10.3	11.2	11.5	12.0	12.4	12.8	13.6	14.2	15.7
E <sub>i</sub>	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
L <sub>Wmi</sub>	77.7	73.0	73.0	71.2	70.7	69.9	66.9	65.1	63.5	70.7	57.5	57.9

Test Conditions at Fan Inlet : Ps actual : 727.8 Pa      density: 1.140 kg/m<sup>3</sup>  
Td1 : 31.1 °C      Pb : 100590 Pa

### Determination Number 4

AMCA Band Number	1			2			3			4		
Center Frequency (Hz)	<u>50</u>	<u>63</u>	<u>80</u>	<u>100</u>	<u>125</u>	<u>160</u>	<u>200</u>	<u>250</u>	<u>315</u>	<u>400</u>	<u>500</u>	<u>630</u>
L <sub>pm</sub>	53.4	60.2	64.2	65.4	70.4	70.3	68.3	69.9	72.3	73.3	69.7	66.1
L <sub>pb</sub>	42.5	38.7	38.7	42.4	42.8	40.2	40.0	37.3	34.5	27.9	25.8	23.9
L <sub>pm</sub> - L <sub>pb</sub>	11.0	21.5	25.5	23.0	27.6	30.2	28.3	32.7	37.8	45.4	43.9	42.3
L <sub>pm</sub> - L <sub>pc</sub>	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
L <sub>pc</sub>	53.1	60.1	64.2	65.4	70.4	70.3	68.3	69.9	72.3	73.3	69.7	66.1
L <sub>Wr</sub> - L <sub>pq</sub>	27.4	18.8	18.0	16.4	13.3	12.4	11.9	10.8	10.3	10.5	9.8	10.1
E <sub>i</sub>	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
L <sub>Wmi</sub>	80.5	79.0	82.2	81.9	83.7	82.7	80.2	80.8	82.6	83.8	79.5	76.2

AMCA Band Number	5			6			7			8		
Center Frequency (Hz)	<u>800</u>	<u>1.0K</u>	<u>1.3K</u>	<u>1.6K</u>	<u>2.0K</u>	<u>2.5K</u>	<u>3.2K</u>	<u>4.0K</u>	<u>5.0K</u>	<u>6.3K</u>	<u>8.0K</u>	<u>10.0K</u>
L <sub>pm</sub>	67.0	64.6	64.1	62.1	60.8	60.7	56.9	55.1	53.0	57.4	45.7	43.8
L <sub>pb</sub>	19.2	17.2	13.1	15.2	9.8	8.7	7.3	6.7	7.3	7.0	7.7	8.4
L <sub>pm</sub> - L <sub>pb</sub>	47.7	47.4	51.0	46.9	51.0	52.0	49.6	48.4	45.7	50.4	38.0	35.4
L <sub>pm</sub> - L <sub>pc</sub>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
L <sub>pc</sub>	67.0	64.6	64.1	62.1	60.8	60.7	56.9	55.1	53.0	57.4	45.7	43.8
L <sub>Wr</sub> - L <sub>pq</sub>	10.1	10.1	10.1	10.3	11.2	11.5	12.0	12.4	12.8	13.6	14.2	15.7
E <sub>i</sub>	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
L <sub>Wmi</sub>	77.1	74.7	74.2	72.4	72.1	72.2	69.0	67.5	65.8	71.0	60.0	59.6

Test Conditions at Fan Inlet : Ps actual : 886.5 Pa      density: 1.140 kg/m<sup>3</sup>  
Td1 : 31.1 °C      Pb : 100590 Pa

## TEST RESULTS

Test Number 28024-S1  
 Purpose Contract Test

Date of Test 29 Oct 2011  
 Technician LTH


AMCA Band Number Center Frequency (Hz)	1	2	3	4	5	6	7	8	Point of Operation		
	<u>63</u>	<u>125</u>	<u>250</u>	<u>500</u>	<u>1.0K</u>	<u>2.0K</u>	<u>4.0K</u>	<u>8.0K</u>	<u>P</u> <sub>s</sub> Pa	<u>Q</u> m <sup>3</sup> /s	<u>N</u> rpm
Det. No. : 1 L <sub>wi</sub> (dB) :	84	89	87	90	86	83	79	73	0	2.75	2000
Det. No. : 2 L <sub>wi</sub> (dB) :	81	86	86	89	84	80	75	72	394	2.31	2000
Det. No. : 3 L <sub>wi</sub> (dB) :	79*	83	83	86	80	75	70	71	766	1.72	2000
Det. No. : 4 L <sub>wi</sub> (dB) :	86	88	86	86	80	77	72	72	933	0.99	2000

These test data were obtained in a laboratory accredited by AMCA for AMCA Standard 300 testing. Data are not certified by AMCA.

**TEST SETUP PICTURE**

Test Unit : Centrifugal  
Manufacturer : Aireng Company  
Trade Name : ABIC  
Model No. : 15D

Test Number : 28024-S1  
Date of Test : 29 Oct 2011



Sound Performance Test  
Figure 2 Setup  
Installation Type : B - Free Inlet, Ducted Outlet

## INSTRUMENT LIST

Test Number: 28024-S1

Date of Test: 29 Oct 2011

Technician: LTH

The following instruments, calibrated as applicable per AMCA standards, were used for this test

### PRESSURE

Instruments	Manufacturer
<input checked="" type="checkbox"/> Static Pressure Transducer FC0332	Furness
<input type="checkbox"/> Total Pressure Transducer FC0332	Furness
<input type="checkbox"/> Static & Total Pressure Transducer FC0332	Furness
<input checked="" type="checkbox"/> Barometric Pressure Transmitter T2114	Comet

### TEMPERATURE

Instruments	Manufacturer
<input type="checkbox"/> RTD Sensor Plane 5-Fig 12	Valutemp
<input type="checkbox"/> RTD Sensor Plane 8-Fig 15	Valutemp
<input checked="" type="checkbox"/> Humidity Transducer TH-200-HN/STH-PD150	Kimo

### SPEED

Instruments	Manufacturer
<input checked="" type="checkbox"/> Speed Meter & Diffuse Reflective Sensor MP5W-44 & BM200-DDT	Autonics

### ELECTRIC METER

Instruments	Manufacturer
<input type="checkbox"/> Multimeter Fluke 322	Fluke
<input type="checkbox"/> Power Meter WT230	Yokogawa

### TORQUE

Instruments	Manufacturer
<input type="checkbox"/> Torque Transducer 1604-200 (5.5kW)	Lebow
<input type="checkbox"/> Torque Transducer 1604-2000 (37kW)	Lebow
<input type="checkbox"/> Strain-Gauge Conditioner Type 3278 Torque Readout	Daytronics

### SOUND

Instruments	Manufacturer
<input checked="" type="checkbox"/> Pulse Data Acquisition & CPB Analysis Types 3560-B-010 & 7771-N2	Bruel & Kjaer
<input checked="" type="checkbox"/> Diffuse-field microphone Type 4943	Bruel & Kjaer
<input checked="" type="checkbox"/> Microphone Preamplifier Type 2669-L	Bruel & Kjaer
<input checked="" type="checkbox"/> Rotating Boom Type 3923	Bruel & Kjaer
<input checked="" type="checkbox"/> Pistonphone for Acoustic Calibration Type 4228	Bruel & Kjaer
<input checked="" type="checkbox"/> Reference Sound Source RSS Type 4204	Bruel & Kjaer
<input checked="" type="checkbox"/> Correction Barometer Type UZ001	Bruel & Kjaer